



200 ft. 8 inch	1990	75	2	1	40.9	\$11,800	\$13,728	\$20,600	2.4%	\$9,380		\$11,220		\$54,278
100 ft. 8 inch (Springs)	2006	75	2	1	56.1	\$6,500	\$6,068	\$12,875	1.4%	\$3,253		\$9,622		\$28,066
120 ft. 6 inch (Pt. Piner)	2009	75	2	1	58.9	\$7,700	\$7,245	\$15,450	1.4%	\$3,317		\$12,133		\$35,040
<b>HDPE SDR-11</b>														
1,838 ft. 6 inch (Pt. Piner)	2008	50	2	1	34.2	\$115,000	\$85,531	\$123,054	0.6%	\$38,885		\$84,169		\$150,989
<b>ASBESTOS-CEMENT</b>														
5,800 ft. 6 inch (99th)	1990	50	2	1	17.1	\$180,000	\$196,888	\$386,250	3.7%	\$254,153		\$132,098		\$718,928
4,960 ft. 4 inch (Sandy Shores)	1990	50	7	1	3.6	\$158,000	\$34,204	\$329,600	3.5%	\$305,869		\$23,731		\$373,055
1,600 ft. 4 inch steel	1990	30	2	1	000	\$53,000	\$0	\$103,000	3.0%	\$103,000		\$0		\$103,000
3735 ft. 2 inch PVC	1990	30	2	1	000	\$121,800	\$0	\$175,000	1.4%	\$175,000		\$0		\$175,000
<b>Distribution Fixtures</b>														
Manzanita Pressure Reducing Station	1986	25	2	1	000	\$20,000	\$0	\$30,000	1.4%	\$30,000		\$0		\$30,000
Manzanita Pressure Relief Improvements	2013	50	1	1	41.0	\$5,000	\$4,646	\$8,652	1.4%	\$1,557		\$7,095		\$15,299
Sandy Shores Pressure Reducing Station	1981	30	7	1	000	\$10,100	\$0	\$30,000	2.9%					
Lower Dockton Pressure Reducing Station	2004	50	2	1	30.4	\$50,000	\$39,044	\$30,900	1.4%	\$12,113		\$18,787		\$47,153
Sandy Shores Pressure Relief Station	2008	50	2	1	34.2	\$5,000	\$5,103	\$6,180	2.9%	\$1,953		\$4,227		\$16,428
112 Valves	1990	50	1	1	18.0	\$112,000	\$62,912	\$118,450	1.4%	\$75,808		\$42,642		\$152,131
6 valves in Windmill Project	2009	75	1	1	62.0	\$5,600	\$5,004	\$5,974	0.6%	\$1,035		\$4,939		\$8,656
5 vales on Dock Loop	2011	75	1	1	64.0	\$4,665	\$4,160	\$4,841	0.4%	\$710		\$4,131		\$6,250
5 valves on 260/Stuckey	2013	75	1	1	66.0	\$5,000	\$4,986	\$5,150	1.4%	\$618		\$4,532		\$12,892
49 Fire Hydrants and valves	1990	50	1	1	18.0	\$140,000	\$78,640	\$350,200	1.4%	\$224,128		\$126,072		\$449,779
1 hydrant at Windmill & Stuckey	2009	75	1	1	62.0	\$2,100	\$1,852	\$6,000	0.5%	\$1,040		\$4,960		\$8,174
2 hydrants on the Dock Loop	2011	75	1	1	64.0	\$4,200	\$3,786	\$12,000	0.5%	\$1,760		\$10,240		\$16,512
4 hydrants on 260/Stuckey	2013	75	1	1	66.0	\$8,400	\$8,377	\$24,000	1.4%	\$2,880		\$21,120		\$60,078
Ten Testing Stations	2000	25	1	1	3.0	\$12,000	\$1,792	\$14,420	1.0%	\$12,690		\$1,730		\$14,857
37 metered services	1980	30	1	1	000	\$17,500	\$0	\$25,235	1.1%	\$25,235		\$0		\$25,235
37 metered services	1981	30	1	1	000	\$18,000	\$0	\$25,235	1.1%	\$25,235		\$0		\$25,235
37 metered services	1982	30	1	1	000	\$18,500	\$0	\$25,235	1.0%	\$25,235		\$0		\$25,235
37 metered services	1983	30	1	1	000	\$19,000	\$0	\$25,235	0.9%	\$25,235		\$0		\$25,235
37 metered services	1984	30	1	1	000	\$19,500	\$0	\$25,235	0.8%	\$25,235		\$0		\$25,235
37 metered services	1985	30	1	1	000	\$20,000	\$0	\$25,235	0.8%	\$25,235		\$0		\$25,235
37 metered services	1986	30	1	1	000	\$20,500	\$0	\$25,235	0.8%	\$25,235		\$0		\$25,235
37 metered services	1987	30	1	1	000	\$21,000	\$0	\$25,235	0.8%	\$25,235		\$0		\$25,235
37 metered services	1988	30	1	1	000	\$21,500	\$0	\$25,235	0.8%	\$25,235		\$0		\$25,235
39 metered services	1989	30	1	1	000	\$23,400	\$0	\$26,780	0.5%	\$26,780		\$0		\$26,780
37 metered services	1990	30	1	1	000	\$22,000	\$0	\$25,235	0.8%	\$25,235		\$0		\$25,235
37 metered services	2018	30	1	1	26.0	\$25,200	\$22,817	\$26,000	1.1%	\$3,467		\$22,533		\$34,554
37 metered services	2019	30	1	1	27.0	\$25,200	\$23,786	\$26,000	1.6%	\$2,600		\$23,400		\$39,912
37 metered services	2020	30	1	1	28.0	\$25,200	\$24,279	\$26,000	1.6%	\$1,733		\$24,267		\$40,551
37 metered services	2021	30	1	1	29.0	\$25,200	\$24,750	\$26,000	1.6%	\$867		\$25,133		\$41,199
5 Metered Services (Windmill)	2009	30	2	1	16.2	\$3,400	\$2,193	\$14,420	1.4%	\$6,657		\$7,763		\$18,050
12 Metered Services (Dock Loop)	2011	30	2	1	18.1	\$8,100	\$5,262	\$8,652	0.7%	\$3,446		\$5,206		\$9,813
21 Metered Services (260/Stuckey)	2013	30	2	1	20.0	\$14,200	\$10,702	\$14,626	1.4%	\$4,900		\$9,726		\$19,301
2 Metered Services(2014)	2014	30	2	1	20.9	\$3,000	\$2,336	\$3,090	1.4%	\$937		\$2,153		\$4,132



**A-1 Condition Assessment**

Condition Rating	Description	Maintenance Level	Condition Multiplier
1	Good/Expected Condition	Normal Preventive	1
2		Maintenance (PM)	0.95
3	Minor Defects Only	Normal PM, Minor	0.8
4		Contract Maintenance (CM)	0.7
5	Moderate Deterioration	Normal PM, Major CM	0.5
6			0.35
7	Significant Deterioration	Major repair,	0.2
8		rehabilitate	0.1
9	Virtually Unserviceable	Rehab unlikely	0.05
10	Unserviceable	Replace	0

**A-2 Critical Number**

Critical Number	Description
1	The water system would essentially shut down if this component fails. This asset has no backup and is so important that an emergency plan must be in place as well as funding to replace it. Example: Single well pump failure; single reservoir failure; anything that could cause a violation of the Safe Drinking Water Act.
2	This asset would have a serious impact on the water system if it failed, however, procedures could fix the problem within a reasonable time. Example: Two wells and primary wellpump fails; Electrical compents in panels fail: backflow assembly did not pass testing; key pipe failure that could be repaired; single chlorinator failure; pressure reducing valve failure.
3	The condition of this asset causes continued unnecessary operational costs to your utility. Examples: deteriorating buildings, equipment and rolling stock; leaks in piping; old and worn-out electrical equipment.
4	This asset's condition or failure may cause inconvenience to customers via reduced service, outages, or minor taste or odor complaints. Examples: excessive leaks, valves frozen partway closed, hydrants not working so flushing cannot be done; poor billing program.
5	These assets have been in service for a long time and their condition may not be well known. Evaluation should take place and a determination made as to what may be needed.