

## Water Use Efficiency Annual Performance Report - 2015

WS Name: DOCKTON WATER ASSOCIATION

Water System ID# : 19550

WS County: KING

Report submitted by: *Lauren Adams*

### Meter Installation Information:

Estimate the percentage of metered connections: *100%*

If not fully metered - Current status of meter installation:

### Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period: *04/30/2015* To *04/30/2016*

Incomplete or missing data for the year? *No*

If yes, explain:

### Distribution System Leakage Summary:

Total Water Produced and Purchased (TP) – Annual Volume	26,746,139 gallons
Authorized Consumption (AC) – Annual Volume	22,441,137 gallons
Distribution System Leakage – Annual Volume TP – AC	4,305,002 gallons
Distribution System Leakage – Percent DSL = $[(TP - AC) / TP] \times 100$	16.1 %
3-year annual average	20.2 %

### Goal-Setting Information:

Date of Most Recent Public Forum: *07/22/2013* Has goal been changed since last performance report? *No*

Note: Customer goal must be re-established every 6 years through a public process

### WUE Goals:

Customer Goal (Demand Side):

*Reduce average annual usage per active customer to less than 6,600 cubic feet by 2016.*

### Describe Progress in Reaching Goals:

Customer (Demand Side) Goal Progress:

*In 2015 our wells production was higher than in 2014. We continue to locate and repair leaks. We continue to educate and encourage consumers to use water wisely and conserve.*

### Additional Information Regarding Supply and Demand Side WUE Efforts

Include any other information that describes how you and your customers use water efficiently:

**Do not mail, fax, or email this report to DOH**