



Date Submitted: 5/9/2017

Water Use Efficiency Annual Performance Report - 2016

WS Name: DOCKTON WATER ASSOCIATION

Water System ID# : 19550

WS County: KING

Report submitted by: *Lauren Adams*

Meter Installation Information:

Estimate the percentage of metered connections: *100%*

If not fully metered - Current status of meter installation:

Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period: *05/01/2016 To 04/30/2017*

Incomplete or missing data for the year? *No*

If yes, explain:

Distribution System Leakage Summary:

Total Water Produced and Purchased (TP) – Annual Volume	23,860,332 gallons
Authorized Consumption (AC) – Annual Volume	20,331,380 gallons
Distribution System Leakage – Annual Volume TP – AC	3,528,952 gallons
Distribution System Leakage – Percent DSL = $[(TP - AC) / TP] \times 100$	14.8 %
3-year annual average	14.6 %

Goal-Setting Information:

Date of Most Recent Public Forum: *07/22/2013* Has goal been changed since last performance report? *No*

Note: Customer goal must be re-established every 6 years through a public process

WUE Goals:

Customer Goal (Demand Side):

Reduce average annual usage per active customer to less than 6,600 cubic feet by 2016.

Describe Progress in Reaching Goals:

Customer (Demand Side) Goal Progress:

In 2016 our wells production was lower than in 2015. We continue to locate and repair leaks. We will continue to educate and encourage consumers to use water wisely and conserve.

Additional Information Regarding Supply and Demand Side WUE Efforts

Include any other information that describes how you and your customers use water efficiently:

Do not mail, fax, or email this report to DOH